



## Jasper County, South Carolina

### ADDENDUM #2

June 13, 2019

### WATER/SEWER UTILITIES for a New Toilet Facility at Sergeant Jasper County Park

#### NOTICE TO ALL POTENTIAL BIDDERS

The Request for Sealed Bids is modified as set forth in this Addendum. The original Request for Bids Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Request. Respondent shall take this Addendum into consideration when preparing and submitting its Bid.

#### SEALED BID SUBMITTAL DEADLINE

The Bid submittal deadline remains the same and is not changed by this Addendum.

#### REQUEST FOR BID

Section	Description of Change
Scope of Work Note 5 on AS-101	Delete the following: "Furnish and install 750 feet of 2" SDR9 HDPE sanitary sewer force main and miscellaneous appurtenances per drawings, from the point of connection at existing BJWSA manhole HD32-024 to the proposed grinder pump station to be supplied by others."  Add the following: "Furnish and install 750 feet of 2" SDR9 HDPE sanitary sewer force main and miscellaneous appurtenances per drawings, from the point of connection at existing BJWSA manhole HD32-024 to the proposed grinder pump station to be supplied by contractor."
Scope of Work Note 6 on AS-101	Delete the following: "Install a Simplex grinder pump station package complete, including connections from the sanitary sewer line from the building to the aforementioned force main."  Add the following: "Furnish and install a Simplex grinder pump station package complete, including connections from the sanitary sewer line from the building to the aforementioned force main."

**END OF ADDENDUM**